



31 (6)

**OFFICE OF THE CORPORATION OF THE CITY, NAGPUR
(FIRE & EMERGENCY SERVICE)**

Chhatrapati Shivaji Maharaj Prashashkiya Bhawan, Mahanagar Palika, Civil lines, Nagpur - 440 001

Ph. No.: 0712-2567777
Fax No.: 0712-2561584

No. FES/1099ICFO.

To,

Sar-La Education Trust
Through Trustee Shri. Chetan Mehrotra
Kh. No. 56/3, 56/4, Mouza - Khasarmari,
Tah., Dist. Nagpur.

Date: 20/06/2018

Sub: - Compliance Certificate.

- Ref :-
- 1) Recommendation Letter No. GA/3211/FB., Date 10/01/2018
 - 2) Your Application Dated 08.06.2018 for Compliance certificate.

Certified that the Educational building having height 8.100 mtr., Ground to 1 Floors and built up area of 6598.966 Sq. Mtr. belonging to Sar-La Education Trust Through Trustee Shri. Chetan Mehrotra At. Kh. No. 56/3, 56/4, Mouza - Khasarmari, Tah., Dist. Nagpur. has complied with the fire prevention and safety measures in accordance with the fire prevention and life safety measures act 2006 (herein after referred as said act.)

This Compliance certificate is issued on the basis of the inspection report of Deputy Chief Fire Officer, Kalamna Fire & Emergency Service dated 12.06.2018 and certificate "A" (as per the provisions of said act 2006) dated 02/06/2018 by the Licensed Agency M/s PS Engineering Services (License No. MFS -LA/RF-0393) regarding the compliance of the fire prevention and life safety measures on following conditions as prescribed in the said act 2006:

1. Under the Sub section (3) of section 3 it is the responsibility of the owner or the occupier as the case may, shall furnish to the Chief Fire Officer a certificate in a prescribed form twice in a year i.e in the month of January and July regarding maintenance of fire prevention and life safety measures in good repair and efficient condition as specified in sub section (1).
2. Under Sub section (4) of section 3, No person shall tamper with alter remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any other person to do so.

P. P. Shende
Principal
Aspire International School
Nagpur



PS ENGINEERING SERVICES PVT. LTD.

Ref. No. PSESPL/AS/FF-006

FORM 'B'

[See Section 3(3) and rule 4(2)]

CERTIFICATE

Certified that we carried out inspection of the Fire Prevention and Life Safety Measures installed in following building or premises, Namely:-

SAR-LA EDUCATION TRUST

Through Trustee Shri. Chetan Mehrotra

Kh. No. 56/3, 56/4, Mouza - Khasarmari, Dist. Nagpur.

We further certified that these installations in the above-mentioned building are maintained in good repair and efficient conditions during the period **01.07.2022 to 31.12.2022** as require under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act. 2006 (Mah. III of 2007). The details of the inspection of installation carried out by us are mentioned in the report appended herewith.

Address of Licensed Agency: PS ENGINEERING SERVICES PVT. LTD.

**Opp. Asha Mangal karyalaya,
Pushpagandha Apartment, Khare Town,
Dharampeth, Nagpur. 440010.**

Date:- 28/06/2022.

License No: MFS/LA/RF-87/RD-85/RP-24

Place:- Nagpur.

Signature

**Komal
Uddhavrao
Mahalle**

Digitally signed by
Komal Uddhavrao
Mahalle
Date: 2022.06.28
12:21:27 +05'30'

**M/s. PS ENGINEERING SERVICES PVT. LTD.
MOB. NO. 7767000215/16.**

Address: Flat No. A-3/68, Opp. Asha Mangal Karyalaya, Pushpagandha Apartment, Khare Town, Dharampeth,
Nagpur- 440 010 (MS) **Website :** www.psengg.com **Email id:** psengg23@gmail.com
PH. No.: 0712-2955166 **Mob. No.:** 7767000211 **CIN:** U29100MH2021PTC359547
GSTIN: 27AALCP9643A1Z9 **PAN:** AALCP9643A **TAN:** NGPP07429C



PS ENGINEERING SERVICES PVT. LTD.

ANNEXURE 'A'

Description of Fire Fighting System Installed in SAR-LA EDUCATION TRUST
Throught Trustee Shri. Chetan Mehrotra Kh. No. 56/3, 56/4, Mouza - Khasarmari, Ta. Dist. Nagpur.
Educational Building (G to 1st Floor) of Height :- 8.100 Mtrs.

Floor	Hydrant Valve	Hose Box	Hose Reel Drum	RRL Pipe 15 Mtr.	Branch Pipe	ABC Extinguisher	CO2	Foam	Alram Panel	Manual Call Point	Hooter	Smoke Detectors	Main Pump 1620 LPM	Jockey Pump 180 LPM	Fire Inlet Connection
	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos	Qty in Nos
Ground Class Rooms & Admin	5	5	3	10	5	6	2	1	0	0	0	0	1	1	1
1st Class Rooms	3	3	3	6	3	4	1	1	0	0	0	0			
Total QTY	8	8	6	16	8	10	3	2	0	0	0	0	1	1	1

Yours Faithfully,

Signature

Komal
Uddhavrao Mahalle
Digitally signed by Komal
Uddhavrao Mahalle
Date: 2022.06.28 12:19:34
+05'30'

License No:-MFS-LA/RF-87 (HYDRANT SYSTEM)
License No. MFS-LA/RD-85 (DETECTION SYSTEM)
License No. MFS-LA/RP-24 (PASSIVE SYSTEM)

For, M/S. PS ENGINEERING SERVICES PVT. LTD.

Address :- A-3/68, Opp. Aasha Mangal Karyalaya, Pushpagandha Apartment, Khare Town, Dharmpeeth, Nagpur 440010.

Web:- www.psengg.com